

* شراء وحدات معالجة مياه لمستشفيات الخدمات الطبيه الملكيه *

01. Complete Ro unit with the Followings Specifications

- net output 1m³/hr.
- product TDS < 5ppm.
- Stainless steel Feed water pump (4m³/hr@ 2bar) with controller.
- Automatic multimedia Filter (13x54) .
- Automatic Carbon Filter (13x54).
- Duplex (13x54) softener unit with all accessories .
- R.O unit (1m³/hr).
- Stainless steel product water Feed pump (2m³/h @ 4bar) Qty (2) with controller.
- Mixed bed (10x33) with TDS online meter.

٠٢ مواد كيميائية لمعالجة البويلرات:

- منشأ : أمريكي أو اوروبي .
- ان تكون المواد مجربه في المستشفيات لمدة (٣) سنوات على الاقل .
- تقديم السعر باللتر على ان يتم تحديد الكمية خلال الاحاله .

- الشروط الخاصة :

- ٠١ التقديم والتركييب في مستشفى الامير علي بن الحسين (الكرك) ومستشفى الامير زيد بن الحسين (الطفيله) .
- ٠٢ تسليم المواد الكيميائية في مستشفى مدينة الحسين الطبيه.
- ٠٣ المنشأ:
- أ. RO membrane أمريكي أو اوروبي .
- ب. Control heads أمريكي.
- ج. باقي المكونات امريكي أو اوروبي .
- ٠٤ تقديم كفالة لمدة سنه.
- ٠٥ تقديم شهادة منشأ.
- ٠٦ عدد وحدات معالجة المياه (٢).